

Display energy certificate (DEC)



HM Government

THAMES HALL
Hardwick Campus
St. Pauls Road
CHELTENHAM
GL50 4BS

Operational rating

C

Certificate number: 2859-1959-6126-2498-2105

Valid until: 29 November 2023

Total useful floor area: 1338 square metres

Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO₂) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Score	Operational rating	This building	Typical
0-25	A	55 C	100
26-50	B		
51-75	C		
76-100	D		
101-125	E		
126-150	F		
150+	G		

Previous operational ratings

Date	Operational rating
November 2022	55 C
November 2021	48 B
October 2020	51 C

Total carbon dioxide (CO₂) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO₂.

Date	Electricity	Heating	Renewables
November 2022	27	37	0
November 2021	24	36	0
October 2020	26	34	0

Assessment details

Assessor's name	Ian Shellard
Employer/Trading name	Esos Energy
Employer/Trading address	5th Floor, Castlemead tower, Lower, Bristol, BS1 3BN
Assessor's declaration	Contractor to the occupier for EPBD services only.
Accreditation scheme	Stroma Certification Ltd
Issue date	2 November 2022
Nominated date	30 November 2022

This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m ² /year)	37.29	143.60
Typical energy use (kWh/m ² /year)	60	281.39
Energy from renewables	0%	0%

