

Display energy certificate (DEC)

ART & PHOTOGRAPHY BUILDING
Hardwick Campus
St. Pauls Road
CHELTENHAM
GL50 4BS

Operational rating

B

Certificate number: 1346-8512-1922-0209-3702

Valid until: 29 November 2022

Total useful floor area: 3473 square metres

Energy performance operational rating

The building's energy performance operational rating is based on its carbon dioxide (CO₂) emissions for the last year.

It is given a score and an operational rating on a scale from A (lowest emissions) to G (highest emissions).

The typical score for a public building is 100. This typical score gives an operational rating of D.

Score	Operational rating	This building	Typical
0-25	A	45 B	100 ..
26-50	B		
51-75	C		
76-100	D		
101-125	E		
126-150	F		
150+	G		

This building's energy use

Energy use	Electricity	Other fuels
Annual energy use (kWh/m ² /year)	43.76	86.27
Typical energy use (kWh/m ² /year)	80	242.11
Energy from renewables	0%	0%

Previous operational ratings

Date	Operational rating
November 2021	45 B
October 2020	35 B
October 2019	37 B

Total carbon dioxide (CO₂) emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO₂.

Date	Electricity	Heating	Renewables
November 2021	84	58	0
October 2020	64	41	0
October 2019	73	42	0

Assessment details

Assessor's name	Adrian Newton
Employer/Trading name	ESOS Energy Ltd
Employer/Trading address	2nd Floor Tower House, Fairfax Street, Bristol, BS1 3BN
Assessor's declaration	Contractor to the occupier for EPBD services only.
Accreditation scheme	CIBSE Certification Limited
Issue date	15 March 2022
Nominated date	30 November 2021

